

## Gas Rough In / Natural Gas Inspection

This inspection is necessary when new or renovated piping for natural gas or propane is installed.

### Prepare

Learn about how to prepare for your [Residential](#) or [Commercial](#) inspection.

### Check

The following are the most common items audited during this inspection. However, the list is not exhaustive. The work must meet all the applicable codes and standards.

- ☐ Piping has been installed and meets the B149.1 Natural gas and Propane Installation Code
- ☐ All piping is exposed for visual inspection; no ground coverage, drywall, insulation, vapour barrier or spray foam has been installed
- ☐ Air test assembly is installed and holding pressure (accessible without a ladder or lift)
- ☐ Piping is properly supported and sized.
- ☐ BTU load and longest-run calculations are available on-site
- ☐ If the roof height is more than 13 feet from ground level, permanent access is required