



## Plumbing - Rough-In Basement or Suite Inspection

This inspection is necessary when new or renovated piping for drainage and water supply is installed in a residential basement and could include ground work and rough-in.

### Prepare

Learn about [how to prepare for your inspection](#).

### Check

Following are the most common items audited during this inspection. However, the list is not exhaustive. The work must meet all the applicable codes and standards.

- ☐ All piping is exposed for visual inspection; no concrete, drywall, insulation, vapor barrier or spray foam have been installed
- ☐ Piping has been installed and meets the National Plumbing Code (NPC) standards:
- ☐ Fixtures below street level are protected with a backwater valve.
- ☐ Pipes have proper grade and adequate support
- ☐ Water supply lines are properly sized.
- ☐ Rough-in valves to be installed and CSA approved.
- ☐ Waterlines and drainage piping is to be protected from freezing.